




## TO WHOMSOEVER IT MY CONCERN

This is to certify that I personally have carried out the Physical inspection of **Health, sanitation and Drinking Water** facilities provided to the students and staff in Mother Teresa Memorial School at Kargaina.kareilly, Bareilly and found them satisfactory.

Place: Bareilly

Date: 31/08/22

  
31/08/22  
प्रभार चिकित्साधिकारी  
न० प्राथमिक स्वी० केन्द्र  
करेली (क्यारा) धरली

	<b>Analysis Report</b>	
	District Level Water Analysis Laboratory U.P.Jal Nigam (RURAL)	
	Near M.B.Inter Collage, Gandhi Nagar, Bareilly (U.P.)	

URN No :- TC996423000000472F

Customer Details	
Office Name and Address	MOTHER TERESA MEMORIAL SCHOOL, KARGAINA , BAREILLY.
Ref Letter No & Date	0. DATE - 16.02.2024 Report No.- LAB/BLY/2023-24/472

Basic details of sample					
District	BAREILLY	Tehseel	BAREILLY	Analysis Start Date	16.02.2024
Village	KARGAINA	Block	KYARA	Analysis Completion Date	16.02.2024
Habitation	KAREILLY	Location	IN SCHOOL	Report Issue Date	16.02.2024
Water Source	RO	Sample Code	PS-472	Sample Depositor	MARYEAPEN
Quantity of Sample	1 ltr	Date of Sample Collection	16.02.2024		
Receiving Date	16.02.2024	Sample Collector	VIPIN KUMAR		

Environmental Condition		
Temperature	24°C	Humidity
		68%

Technical Data of Analysis						
S.No.	Analysis Parameter	Unit of Measurement	Observed Value	Specified Values as per IS 10500:2012		Ref.Method of Analysis
				Acceptable Limit	Permissible Limit	
1	2	3	4	5	6	7
1	Colour	(Hazen)	0	5	15	IS 3025 (Part 4):2021
2	Odour	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022
3	Taste	-	Agreeable	Agreeable	Agreeable	IS:3025(Part-5):2022
4	Turbidity	(NTU)	0.23	1.00	5.00	IS 3025 (Part 10) : 2022
5	TDS	(mg/L)	75	500	2000	IS 3025 (Part 16) : 2022
6	PH	-	7.72	6.5-8.5	6.5-8.5	IS 3025 (Part 11) :2022
7	Iron	(mg/L)	0.1	1.00	1.00	IS:3025(Part-53):2014
8	Sulphate	(mg/L)	6.5	200	400	IS 3025 (Part 24) : 2022
9	Alkalinity	(mg/L)	38	200	600	IS 3025 (Part 23) : 2019
10	Hardness	(mg/L)	48	200	600	IS 3025 (Part 21) : 2019
11	Chloride	(mg/L)	4	250	1000	IS 3025 (Part 32) : 2019
12	Calcium	(mg/L)	24	75	200	IS:3025(Part-40):2019
13	Magnesium	(mg/L)	5.8	30	100	APHA 24th Edition 3500Mg Method B
14	Fluoride	(mg/L)	-	1	1.5	IS:3025 (Part-60):2023
15	Nitrate	(mg/L)	-	45	No relaxation	APHA 24th Edition 4500 Method B

- Note**
- This Certificate refers only to the particular sample(s) submitted for testing.
  - This certificate shall not be reproduced, except in full, unless written permission for the publication of an approved abstract has been obtained from Head of Laboratory.
  - The test results reported in this certificate are valid at the time of and under the stated conditions of measurements.
  - Sample will be stored up to 07 days (in case of non perishable items only) from the date of issue of tests reports unless otherwise specified.

• Not in NABL Scop

Email - anamika0sanu@gmail.com  
U.P.J.N.BAREILLY (RURAL) Cont.No:- 7318253236

Prepared By  
**आनेल कुमार**  
 गुणवत्ता प्रबन्धक  
 जल विश्लेषण प्रयोगशाला  
 उ० प्र० जल निगम बरेली (ग्रामीण)

मात.  
 21/2/2024


Approved By  
**Anamika**  
 Technical Manager  
 District Level Water Testing Laboratory  
 U.P.J.N. Bareilly

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.

Dated:

It is certified that an inspection team headed by DR. RAJNIKANT NEERAJ  
(Name of Officers with designation) from Medical officer  
(Name of Department/ Office) inspected the Health department  
(Name & Address of the school) on 27/06/23 (date of inspection), checked the water test report submitted by the school and found that the school has potable drinking water for students and staff of the institution and is having provision for running water in the toilets and maintaining hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.  
The above is valid for a period of 12 months.

Signature with Seal:   
Name : Dr. Rajnikant Neeraj  
Designation : Medical officer

Assistant Engineer of  
The Govt. Public Health Department (PHED)/  
Authorised officer of the Local Body

Name & Address of the Office / Department : .....

PHC Korli, Bareilly.

To

Mother Teresa Memorial School  
Korli, Bareilly.

(Name & Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.